


**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**
**CB TEST CERTIFICATE**

Product	Independent LED driver
Name and address of the applicant	MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248 Taiwan
Name and address of the manufacturer	MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248 Taiwan
Name and address of the factory	<input checked="" type="checkbox"/> <a href="#">Additional information on page 2</a> MEAN WELL (Guangzhou) Electronics Co. Ltd. Huadu Branch No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, Guangdong China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	Class I, ta: 60 °C, tc: 90 °C, λ: 0,95, SELV Independent controlgears, Non-Inherently short-circuit proof, 110 °C thermal protection, MM mark; ELG-100-CXY (X=1050, 1400, Y=blank, A, B, AB, D, D2, DA, ADA, AD2): Constant current; ELG-100-XY (X=24, 36, 42, 48, 54, Y=blank, A, B, AB, D, D2, DA, ADA, AD2): Constant voltage; IP65 for model ELG-100-CXY (X=1050, 1400, Y=A, AB, ADA, AD2), ELG-100-XY (X=24, 36, 42, 48, 54, Y=A, AB, ADA, AD2) IP67 for model ELG-100-CXY (X=1050, 1400, Y= blank, B, D, D2, DA), ELG-100-XY (X= 24, 36, 42, 48, 54, Y= blank, B, D, D2, DA) (Details refer to General product information of test report.)
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	ELG-100-CXY (X=1050, 1400, Y=blank, A, B, AB, D, D2, DA, ADA, AD2) ELG-100-XY (X= 24, 36, 42, 48, 54, Y=blank, A, B, AB, D, D2, DA, ADA, AD2)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> <a href="#">Additional information on page 2</a> This CB Test Certification is an addition to CB NL-42344 with Test Report Number 4329184.50 dated 2016-07-18 due to updated factory information, standards, deviations and rating label.
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 <b>National differences:</b> EU Group Differences, EU Special National Conditions, AU, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	4343528.50

This CB Test Certificate is issued by the National Certification Body

 DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Additional factory

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd, Wugu Dist, New Taipei City 248  
Taiwan

Suzhou MEAN WELL Technology Co., Ltd.  
No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town,  
Xiang-cheng Dist, Suzhou, 215152 Jiangsu  
China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

