



UK Declaration of Conformity

For the following equipment :

Product Name: Switching Power Supply

Model Designation: NPX-750-Y (X=P,B;Y=12,24,48)

The designated product(s) is(are) in conformity with the relevant legislation:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012: SI 2012 No. 3032

Electrical Equipment (Safety) Regulations 2016 :

BS EN 62368-1:2014+A11:2017

Dekra certificate : 31-119445

BS EN 60335-1:2012+A11:2014+A13:2017+A1:2019+A14:2019+A2:2019+A15:2021 Dekra certificate : 31-119442

BS EN 60335-2-29:2021+A1:2021

Electrical Compatibility Regulations 2016 :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

BS EN 55032:2015+A1:2020

Class B

BS EN IEC 55014-1:2021

Harmonic current

BS EN IEC 61000-3-2:2019+A1:2021

Voltage flicker

BS EN 61000-3-3:2013+A1:2019+A2:2021

EMS (Electro-Magnetic Susceptibility)

BS EN IEC 55014-2:2021 BS EN 55035:2017+A11:2020

ESD air

BS EN 61000-4-2:2009

Level 3

8KV

ESD contact

BS EN 61000-4-2:2009

Level 2

4KV

RF field susceptibility

BS EN IEC 61000-4-3:2020

Level 2

3V/m

EFT bursts

BS EN 61000-4-4:2012

Level 2

1KV/5KHz

Surge susceptibility

BS EN 61000-4-5:2014+A1:2017

Level 3

1KV/Line-Line

Surge susceptibility

BS EN 61000-4-5:2014+A1:2017

Level 3

2KV/Line-Earth

Conducted susceptibility

BS EN 61000-4-6:2014

Level 2

3V

Magnetic field immunity

BS EN 61000-4-8:2010

Level 1

1A/m

Voltage dip, interruption

BS EN IEC 61000-4-11:2020

<5% residual voltage for 0.5 cycles ,70% residual voltage for 25 cycles ,
<5% residual voltage for 250 cycles

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Regulations on the complete system again. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File). All the EMC tests require the adding a 13*26*30 NiZn magnetic clasp or magnetic ring to the output line.

This Declaration is effective from serial number SC4xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Eris Wu/ Director, Group R&D :

(Name / Position)

(Signature)

Alex Tsai/ Director, Product Strategy Center :

(Name / Position)

(Signature)

Taiwan

(Place)

May. 15th, 2024

(Date)