



# Test Report : SGA60x18

---

AC-DC High Reliability Interchangeable Medical Adaptor

## ■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

## ■ SAFETY TEST

Safety Test

## ■ RELIABILITY TEST

Other test

## DESIGN VERIFY TEST

### OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	RIPPLE & NOISE	80 mVp-p (Max)	I/P:230VAC O/P:FULL LOAD Ta:25°C	35 mVp-p	P
2	VOLTAGE TOLERANCE	-2% ~ +2% (Max)	I/P:90VAC~264VAC O/P:FULL~MIN. LOAD Ta:25°C	-1.02% ~ +1.08%	P
3	LINE REGULATION	-1% ~ +1% (Max)	I/P:90VAC ~264VAC O/P:FULL LOAD Ta:25°C	-0.03% ~ +0.03%	P
4	LOAD REGULATION	-2% ~ +2% (Max)	I/P:230VAC O/P:FULL ~MIN LOAD Ta:25°C	-1.01% ~ +1.07%	P
5	SET UP TIME	500 mS	I/P:230VAC O/P:FULL LOAD Ta:25°C	119.8 mS	P
6	RISE TIME	50 mS	I/P:230VAC O/P:FULL LOAD Ta:25°C	9.79 mS	P
7	HOLD UP TIME	12 mS (Min)	I/P:115VAC O/P:FULL LOAD Ta:25°C	30.4 mS	P

### INPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	VOLTAGE RANGE	90VAC ~ 264VAC	I/P:TESTING O/P:FULL LOAD Ta:25°C	54V ~ 264V	P
2	FREQUENCY RANGE	50HZ - 60HZ (Typ) NO DAMAGE OSC	I/P: 100VAC ~ 240VAC O/P:FULL~MIN LOAD Ta:25°C	TEST: OK	P
3	EFFICIENCY	88% (Typ)	I/P:230VAC O/P:FULL LOAD Ta:25°C	89.34%	P
4	AVERAGE EFFICIENCY	88%@115VAC 89%@230VAC	I/P:115/230VAC O/P:25%、50%、75%、100% LOAD Ta:25°C	89.75% (115VAC) 89.61% (230VAC)	P
5	AC CURRENT	1.5A (Max)	I/P: 100VAC O/P:FULL LOAD Ta:25°C	1.02 A	P
6	NO LOAD POWER CONSUMPTION	< 0.15W (Max)	I/P:230VAC O/P: NO LOAD Ta:25°C	0.0465 W	P

7	INRUSH CURRENT	< 80A COLD START	I/P:230VAC O/P:FULL LOAD Ta:25°C	75.7A	P
8	LEAKAGE CURRENT	< 0.25mA	I/P:240VAC O/P:Min LOAD Ta:25°C	L-FG: 0.02mA N-FG: 0.02mA	P

## PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	110% ~ 200%	I/P:230VAC O/P:TESTING Ta:25°C	150% HICCUP MODE RESET : AUTO RECOVER	P
2	OVER VOLTAGE PROTECTION	110% ~ 140%	I/P:230VAC O/P:MIN LOAD Ta:25°C	123% (MMSZ5251B ) Clamp by ZENER diode	P
3	SHORT PROTECTION	SHORT OUTPUT 1 HOUR NO DAMAGE	I/P:264VAC O/P:FULL LOAD Ta:25°C	NO DAMAGE HICCUP MODE RESET AUTO RECOVER	P

## ■ SAFETY TEST

### SAFETY TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P:4242 VDC/min	I/P-O/P:4242 VDC/min Ta:25°C	I/P-O/P: 0.03uA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ	I/P-O/P:500 VDC Ta:25°C	I/P-O/P>100MΩ NO DAMAGE	P

## ■ RELIABILITY TEST

### OTHER

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	MTBF	MIL-KDBK-217F NOTICES 2 PARTS COUNT TOTAL FAILURE RATE : 2.134442 M.T.B.F : 468506 HRS			P

TEST RESULT	TESTER	APPROVAL
PASS	PETER CHENG	VINCENT TSENG