



Ref. Certif. No.

DE 2-038820

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCHING POWER SUPPLY

Name and address of the applicant

MEAN WELL Enterprises Co.,Ltd.  
No. 28, Wuquan 3rd Rd. Wugu District  
New Taipei City 24891 Taiwan

Name and address of the manufacturer

MEAN WELL Enterprises Co.,Ltd.  
No. 28, Wuquan 3rd Rd. Wugu District  
New Taipei City 24891 Taiwan

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

AC Input : 100-240V, 50/60Hz, 1.8A (x = 3.3) ;  
100-240V, 50/60Hz, 2.4A (x = 4.2) ;  
100-240V, 50/60Hz, 2.6A (x = 5, 12, 15, 24, 36, 48, 55) ;  
Class I  
DC Output: Refer to page 2

Trademark (if any)

MEAN WELL (Logo)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

UHP-200R-x, UHP-200-x  
(x = 3.3, 4.2, 5, 12, 15, 24, 36, 48, 55)

Additional information (if necessary may also be reported on page 2)

For model differences, refer to the test report.

A sample of the product was tested and found to be in conformity with

IEC 61558-2-16:2009+A1  
IEC 61558-1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

CN23T9CJ 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland LGA Products GmbH  
Tillystr. 2, 90431 Nürnberg, Germany  
Phone + 49 221 806-1371  
Fax + 49 221 806-3935  
Mail: cert-validity@de.tuv.com  
Web : www.tuv.com

Date: 2023-03-31

Signature:

Spark Li

1. MEAN WELL Enterprises Co.,Ltd.  
No. 28, Wuquan 3rd Rd. Wugu District  
New Taipei City 24891  
Taiwan
2. Suzhou MEAN WELL Technology Co., Ltd.  
No.269, Changping Road, Huangdai Town,  
Xiangcheng District, Suzhou  
Jiangsu  
P.R. China
3. MEAN WELL (GUANGZHOU) Electronics Co., Ltd.  
No. 11 Jingu South Road, Huadu District,  
Guangzhou  
510890 Guangdong, P.R. China
4. Yongden Technology Corporation  
345 MacArthur Highway, Tabang,  
Guiguinto, Bulacan 3015  
Philippines
5. MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED  
9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA,  
Bengaluru (Bangalore) Urban, Karnataka, 560058  
India

**Additional information (if necessary)**

Report Ref. No. : CN23T9CJ 001

DC Output:

3.3V, 40.0A, 132.0W; 4.2V, 40.0A, 168.0W;  
5.0V, 40.0A, 200.0W; 12.0V, 16.7A, 200.4W;  
15.0V, 13.4A, 201.0W; 24.0V, 8.4A, 201.6W;  
36.0V, 5.6A, 201.6W; 48.0V, 4.2A, 201.6W;  
55.0V, 3.6A, 198.0W;



Date: 2023-03-31

Signature:

Spark Li